

## Accepted Manuscript

Title: Small Hydropower Plants in Spain: a Case Study

Authors: C. Alonso-Tristán, D. González-Peña, M. Díez-Mediavilla, M. Rodríguez-Amigo, T. García-Calderón.


PII: S1364-0321(11)00132-8  
DOI: doi:10.1016/j.rser.2011.03.029  
Reference: RSER 1330

To appear in:

Received date: 26-12-2010  
Accepted date: 13-3-2011

Please cite this article as: Alonso-Tristán C, González-Peña D, Díez-Mediavilla M, Rodríguez-Amigo M, García-Calderón. T, Small Hydropower Plants in Spain: a Case Study, *Renewable and Sustainable Energy Reviews* (2010), doi:10.1016/j.rser.2011.03.029

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.



## Small Hydropower Plants in Spain: a Case Study

C. Alonso-Tristán\*, D. González-Peña, M. Díez-Mediavilla, M. Rodríguez-Amigo, T. García-Calderón.  
*Research Group SWIFT (Solar and Wind Feasibility Technologies). University of Burgos. Escuela  
Politécnica Superior. Avda. Cantabria s/n, 09006, Burgos. Spain*

### ABSTRACT

A small hydropower plant in Spain is studied from an energetic and economic perspective. The viability of the facility is examined using the freeware software RETScreen. Calculated and standard operational data are compared, thereby demonstrating the feasibility of the project from all points of view. The study highlights the growing interest in renewable energies.

Keywords: feasibility study, small hydropower, RETScreen, economic study.

### 1. Overview of the European Small Hydropower Sector

Small-scale hydropower is one of the most cost-effective energy technologies to be considered for rural electrification programmes in less-developed countries. It is also the main prospect for future hydro developments in Europe, where large-scale opportunities have either already been exploited, or would now be considered environmentally unacceptable.

In 2006, small hydropower (SHP) generated 41000 GWh of electricity and accounted for over 13000 MW of installed capacity in EU-27 which is enough to supply electricity to over 12 million households. This contributes to annual avoidance of CO<sub>2</sub> by 29 million tonnes, which translates into annual avoided CO<sub>2</sub> costs of about 377 M€ [1]

Hydropower is very dependent on a country's geography. This is demonstrated by the fact that over 90 % of installed small hydropower capacity is concentrated in six member states of the EU-27: Italy, France, Spain, Germany, Austria and Sweden. In addition, Switzerland and Norway have a high SHP capacity, while the largest capacities in the new member states are in Bulgaria, the Czech Republic, Poland and Romania [1]. About 70 percent of economically feasible hydropower potential remains undeveloped in the world.

In 2006 there were nearly 21,000 SHP plants in the EU-27 and when Norway, Switzerland, Bosnia & Herzegovina and Montenegro are included, the number of SHP plants increases to a total of nearly 23,000. The range of investment costs can vary from 1,000 €/kW (Greece, Spain, Bulgaria, Czech Republic, Estonia) to 12,000 €/kW (Germany). In terms of average SHP production cost, the range varies from 0.4 ¢cent/kWh (Bulgaria) to 17.4 ¢cents/kWh (Italy) [2].

#### 1.1. SHP in Spain

Total hydropower electricity generated in Spain in 2009 was 23,862 GWh and 23% of this was produced by SHP facilities (5483 GWh) [3]. Total installed hydropower is 18,682 MW of which 1,974 MW (10.6%) is SHP. The regional distribution of

---

\* Corresponding author. Tel: 34 947 258925. Fax: 34 947 258910  
E-mail address: [catristan@ubu.es](mailto:catristan@ubu.es) (C. Alonso-Tristán)

1 hydropower capacity is presented in Figure 1. The only evaluation of the SHP stations  
2 distributed throughout hydrographical river basins in Spain was completed in 1980 [4],  
3 from which it is assumed that the SHP potential is about 30,000 GWh/year. In 2009,  
4 hydropower supplied 1.7% of Spain's primary energy needs and 2.3% of its demand for  
5 electricity.  
6

7  
8 Development of renewable energies is a priority to which Spanish energy policy is  
9 committed. The National Action Plan for Renewable Energy in Spain (PANER) [5] is  
10 responsive to the requirements and methodology of the European Commission Directive  
11 2009/28/CE [6] which set a binding target of 20% of total consumption from renewable  
12 energy sources by 2020. Within the European Commission, the Spanish model is a  
13 successful example of policies designed to promote renewables. The principle result is  
14 the volume attained by renewable electricity, which has established a structural position  
15 of the first order. In 2009, renewable technologies accounted for approximately 25% of  
16 total electricity generation and 12.2% of the gross final energy consumption in Spain.  
17

18  
19 The country's regulatory framework for electricity generation with renewable energies  
20 is structured through a feed-in tariff system. This operates by securing the payment of a  
21 tariff at the wholesale market price for superior technology. The additional financing is  
22 generated by levying the electricity tariff of individual users. Instead of an ordinary  
23 system of direct subsidies to producers, the costs are shared between conventional  
24 energy producers and consumers, in such a way that the resulting market price of  
25 electric energy production is reduced owing to the prioritization of renewable sources  
26 that enter the electricity production system. Therefore, consumers only finance  
27 renewable producers in sectors that are not covered by this effect.  
28

29  
30 Law 54/1997[7] of the Electrical Sector specifies two regimes for electrical generation:  
31

- 32 – Ordinary Regime for conventional power stations and
- 33 – Special Regime.

34  
35 Special regime generation activity includes electricity generation in power installations  
36 not exceeding 50 MW using renewable energy as the primary source of energy, or waste  
37 and those power installations that involve cogeneration as a technology with a high  
38 level of efficiency and considerable energy saving. This activity has economic and legal  
39 statutory benefits compared with the ordinary system that applies to conventional  
40 technologies. These facilities are regulated by the Royal Decree 661/2007 [8]. Two  
41 tariff systems exist with regard to repayment for renewable energies, which also apply  
42 to mini-hydro power installations:  
43

- 44 – Fixed tariff: for renewable energies, established in different Royal Decrees on an  
45 annual basis.
- 46 – Variable tariff: market price plus a premium and a quality complement.

47  
48 The evolution of the fixed tariff, the most widely chosen during the last ten years  
49 throughout the SHP sector, is presented in Table 1. Among the measures that will boost  
50 future development is, primarily, the maintenance of an effective tariff system. The only  
51 quantitative evolution of the sector is from mini-power stations connected to the grid.  
52 Thus, the National Action Plan for Renewable Energy in Spain (PANER) [5] proposed  
53

1 regulatory measures designed to promote new SHP facilities and financial measures in  
2 order to improve and modernize existing facilities nearing the end of their useful life.  
3

4  
5 In this work, a case study of a small hydropower plant in Spain is presented. The SHP  
6 facility belongs to a small energy company that operates under a Special Regime for  
7 electricity production. It has been fully operational for 10 years. In the first place, this  
8 case study describes the SHP plant, and it goes on to examine the economic aspects of  
9 electricity production, its associated costs, and relevant grants and financial subsidies.  
10 The viability project of the facility has been simulated from RETScreen [9], comparing  
11 the real data to other possible economic scenarios. The results demonstrate, beyond  
12 doubt, the viability of small hydro power plants, even under unfavourable economic  
13 scenarios for investment.  
14  
15

## 16 **2. The SHP Case Study in Spain**

### 17 **2.1. The facility description**

18  
19 The SHP case study (Astuwatt) is located on the banks of the River Pisuerga, in the  
20 town of Astudillo (Palencia), at the centre of the autonomous region of Castilla y León  
21 in Spain. It is a 400 kW grid-connected run-of-river type SHP plant with no dam or  
22 water storage. Its 640 m long trapezoidal bypass channel falls a total of 2.9 vertical  
23 metres over its total length. The widths at the bottom and at the top of the channel are 6  
24 metres and 12 metres, respectively. Once turbinated, the flow is channelled back to the  
25 main river. The aerial photographs in Figure 2 illustrate (a) the plant, (b) the bypass  
26 channel and (c) the return to the main river.  
27  
28  
29  
30  
31

32 The bypass channel was constructed by modifying an old irrigation channel. The bottom  
33 of the channel is sandy and only the final 150 m of its 640 m length, are to minimize  
34 loss through erosion. The plant is environmentally integrated [10] and therefore poses  
35 no threat to the indigenous flora and fauna.  
36  
37

38 The plant employs two 200 kW semi-Kaplan turbines, specifically designed for the  
39 project, that are 1.5 m in diameter, with an internal adjustable turbine runner tilted 15  
40 degrees from the horizontal. The design flow is  $9 \text{ m}^3/\text{sec}$ . A multiplier element is used  
41 to adjust the speed of the turbine (190 rpm) to the speed of the electric generator (750  
42 rpm). There are two 200 kW generators (Abb Motors, model M2BA 355 MLA8), one of  
43 which is specifically for the turbine. The output voltage of this generator is 400 V and a  
44 transformation system is used to convert the electricity to high voltage for input to the  
45 grid. An automatic system controls all mechanical components and records production  
46 data. Figure 3 shows the turbines and the control system.  
47  
48  
49  
50

### 51 **2.2. Economic Data for the Case Study**

52 The project grant for the operation was awarded in 1990 but it was not possible to  
53 complete the administrative process and fulfil all the necessary administrative  
54 requirements relating to permits until 1997. The running time was approximately 15  
55 months and the system was powered up in June 1998.  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65

1 The final price of the installation amounted to 1 M€, of which 30% of the total cost was  
2 financed through a bank loan with an interest rate of 9% for 7 years and a grant  
3 amounting to €24,000 was received from the Government of Castilla y León. Annual  
4 expenditure currently amounts to €32,000, which includes maintenance, staff costs and  
5 insurance.  
6

7  
8 Table 2 shows monthly electrical production from the outset of its functioning until  
9 2009 and total annual electrical production is presented in Figure 4. The facility tariffs  
10 its production at a fixed tariff, noted in Table 1. Since the outset, the installation has  
11 functioned for an average of 3,135 hours per year, except during 2001, when the plant  
12 needed repairs following extensive flooding. This value is within the range of the  
13 technology and the design flow [11] used in the project. However, the price per kW  
14 installed (2500€/kW) is higher than the average estimated by industry associations [2].  
15 This is mainly due to increased costs associated with the use of self-designed turbines,  
16 which required the adaptation of other elements in the plant and the use of two turbines  
17 instead of one, in order to adjust the capacity of the facility to the river flow.  
18  
19  
20  
21

### 22 **3. RETScreen Study of the Facility**

23  
24 The previous section presented a case for a viable and cost-effective installation in a  
25 particular economic scenario. Opportunities for implementing commercially viable,  
26 energy efficient and renewable energy technologies (RETs) are often missed these days,  
27 because many planners and decision-makers still do not routinely consider them at the  
28 critically important, initial planning stage, even though technologies such as small  
29 hydropower installations have proven their reliability and cost-effectiveness in similar  
30 situations elsewhere. Specific procedures regarding design and economic viability  
31 studies of small hydropower plant projects have been developed [12-14], in order to  
32 address and integrate at a pre-feasibility, planning stage, perspectives that consider all  
33 the potential obstacles that can arise.  
34  
35  
36  
37

38 RETScreen software [9, 15] is capable of assessing RETs viability factors such as  
39 energy resources available at the project site, equipment performance, initial project  
40 costs, “base case” credits, on-going and periodic project costs, avoided cost of energy,  
41 financing, taxes on equipment and income (or savings), environmental characteristics of  
42 energy displaced, environmental credits and/or subsidies and decision-maker defined  
43 cost-effectiveness.  
44  
45  
46

47 Moreover, the RETScreen software integrates a series of databases that help to  
48 overcome the costs and difficulties associated with gathering meteorological data,  
49 product performance data, etc. Hence, worldwide meteorological data has been  
50 incorporated directly into the RETScreen software. This meteorological database  
51 includes both the ground-based meteorological data and NASA’s satellite-derived  
52 meteorological data sets. The RETScreen’s hydroelectric model can be used anywhere  
53 in the world, but the only available hydrological data is from Canada. However, the user  
54 can introduce data from any other source. The software has been widely used to study  
55 all types of renewable energies including: small hydropower [16], photovoltaic power  
56 [17, 18], solar water heaters [19], wind and small wind projects [20], combined heat and  
57 power facilities [21], hybrid systems [22], among others. The application of this tool for  
58  
59  
60  
61  
62  
63  
64  
65

1 the proposed case study will demonstrate its capacity to perform pre-feasibility studies  
2 anywhere in the world and will expand the study for application in other design options  
3 and financing as well as different economic scenarios.  
4

5  
6 Seven worksheets are provided in the small hydro project workbook file:

- 7 – Energy Model;
- 8 – Hydrology Analysis & Load Calculation;
- 9 – Equipment Data;
- 10 – Cost Analysis;
- 11 – Greenhouse Gas Emission Reduction Analysis;
- 12 – Financial Summary;
- 13 – Sensitivity & Risk Analysis

14  
15 Fig. 5 presents a flow diagram of the computerized RET's assessment tool. Greenhouse  
16 Gas Emission Reduction and Sensitivity & Risk analyses are optional.  
17  
18

### 19 20 21 **3.1. The Energy model**

22 The first step, referred to as the “energy model”, requires the user to collect basic  
23 information concerning the site conditions as may be necessary: latitude and longitude,  
24 available head, or drop in elevation. These data are presented in Table 3 in relation to  
25 this case study.  
26

### 27 28 **3.2. Hydrology Analysis & Load Calculation**

29 RETScreen calculates the estimated renewable energy delivered for SHP projects, based  
30 on the adjusted available flow (adjusted flow-duration curve), the design flow, the  
31 residual flow, the load (load-duration curve), the gross head and the efficiencies/losses.  
32

33  
34 The flow-duration curve of the River Pisuerga in the facility site has been calculated  
35 from data compiled by the Confederación Hidrográfica del Duero [23], the results of  
36 which are presented in Figure 6. It also includes the design flow of the turbines and the  
37 biological indicators of the river flow.  
38

### 39 40 **3.3. Equipment Data**

41 The data on small hydro turbine efficiency can be entered manually or can be calculated  
42 by RETScreen. Turbine performance is calculated at regular intervals on the flow-  
43 duration curve. Plant capacity is then calculated and the power-duration curve is  
44 established. Available energy is simply calculated by integrating the power-duration  
45 curve. In the case of a central-grid, the energy delivered is equal to the energy available.  
46 The calculation involves comparing the daily renewable hydro-energy available to the  
47 daily load-duration curve for each of the flow-duration curve values.  
48

49  
50 For this case study, the efficiency as a function of the flow-duration curve and the  
51 number of functioning turbines is presented in Figure 7 and a summary of results in  
52 Table 4 and Table 5.  
53

### 54 55 **3.4. Cost Analysis**

56  
57  
58  
59  
60  
61  
62  
63  
64  
65

1 During the “cost analysis” step, a detailed cost analysis is performed taking into  
2 account initial costs and annual costs (maintenance, staff and insurances) involved in  
3 the project. Figure 8 presents the distribution of initial expenses.  
4

### 5 **3.5. Greenhouse Gas Emission Reduction Analysis**

6 The RETScreen has the capacity to estimate the amount of green house gases (GHG),  
7 which could be avoided as a result of using renewable energy sources. The required  
8 input data is the fuel type used in the specific country in question, which is selected as  
9 “All fuel types” and the Transport and Distribution Losses are calculated at 7.5% for  
10 Spain, as a developed country. The model GHG emission factor is estimated to be 0.411  
11 tCO<sub>2</sub>/MWh and the net annual GHG emission reduction is 607.4 tCO<sub>2</sub>/year.  
12  
13  
14

### 15 **3.6. Financial Summary**

16 A number of different economic and financial feasibility indices were calculated such as  
17 the year-to-positive cash flow, Internal Rate of Return (IRR), Return on Investment  
18 (ROI), and Net Present Value (NPV). The results are presented in Figure 9, in which the  
19 calculated RETScreen accumulated cash flow results over 50 years of operation can be  
20 compared with the usual ones over the 10 years of operation. Table 6 summarises these  
21 results. The RETScreen calculations are based on 4.54% after-tax IRR assets and a  
22 simple payback over 11.2 years, while the real results over 10 years are 4.1% and 12.5  
23 years of payback. NPV for the plant is €2,349,625, very close to the calculated figure,  
24 drawn from an extrapolation of the actual data which amounts to €2,012,466.  
25  
26  
27  
28

### 29 **3.7. Sensitivity & Risk Analysis**

30 Different economic scenarios were studied in order to indicate the viability of the  
31 installation, by varying the electricity price (EP) and the CPI (Consumer Price Index).  
32 CPI affects the annual cost of the plant (insurance, staff and maintenance). The  
33 electricity price is fixed every year according to economic and political parameters.  
34 Assuming that the plant has a lifetime of 50 years, the minimum EP increment was  
35 calculated in order to offset the increased fixed costs incurred by the CPI. The  
36 electricity price was adjusted in accordance with the annual fixed tariff referred to as the  
37 CPI, with or without governmental subvention. The CPI was calculated on the basis of a  
38 fixed annual increase of 2% or a variable limited rate of ±2% annually. As results of  
39 these calculations a revalorization of EP slightly lower than the CPI (98%) is necessary  
40 in order to achieve a positive IRR.  
41  
42  
43  
44

## 45 **4. Conclusions**

46 In this paper, a real case of a 400 kW grid-connected SHP plant has been presented. The  
47 installation has functioned at full capacity over the past ten years and has presented  
48 positive energy efficient, environmental and economic results. The total amount of  
49 generated electricity amounted to 17,070.4 MW at the end of 2009 and the plant has  
50 avoided the emission of 607.2 TnCO<sub>2</sub>/year. A total repayment period of twelve years  
51 was calculated, after allowing for financial subsidies and grants. The installation is  
52 assumed to have estimated lifetime of 50 years.  
53  
54  
55  
56

57 A pre-feasibility study was conducted using RETScreen software in order to extend the  
58 case study to other economic scenarios and demonstrate the viability of these types of  
59  
60  
61  
62  
63  
64  
65

1 projects. The energetic and economic results generated by the RETScreen software  
2 closely approximate the usual ones, which demonstrates the capacity of the RETScreen  
3 to analyse small hydro projects. The estimated energy production cost is 5 c€/kWh, a  
4 value within the margins calculated by various industrial associations that work in the  
5 sector [24].  
6

7  
8 The sensitivity analysis that changes the economic variables has demonstrated that the  
9 installation is, from an economic point of view, profitable, even without the feed-in-  
10 tariff subvention system, provided that the electricity price is adjusted to the CPI  
11 changes. However, all of the advantages outlined in this study are in stark contrast to  
12 problems over drawn out administrative procedures and red-tape in the various local and  
13 regional authorities when processing permits, and granting licenses and environmental  
14 concessions. A centralized procedure is clearly required, which would facilitate the  
15 implementation of facilities and prevent delays and loss of competitiveness.  
16  
17  
18

### 19 **Acknowledgments**

20 The present study was carried out under the research project BU019A08 supported by  
21 the Department of Culture and Education of the Regional Government of Castilla y  
22 León, Spain. The authors are also grateful for the cooperation offered by Asturwat, the  
23 company responsible for the SHP installation described in this article.  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65



## Bibliography

- [1] European Small Hydropower Association ESHA *Current status of Small Hydropower development in the EU-27*. 2010; Available from: <http://www.streammap.esha.be/6.0.html>.
- [2] European Small Hydropower Association ESHA. *Small Hydropower Energy Efficiency Campaign Action (SHERPA). Strategic Study for the Development of Small Hydro Power (SHP) in the European Union*. 2008; Available from: <http://www.esha.be/>.
- [3] Red Eléctrica de España. *El sistema Eléctrico Español*. Informes del Sistema Eléctrico 2009; Available from: [www.ree.es](http://www.ree.es).
- [4] *The plan of renewable energies 2005–2010. Spain, August 2005*.
- [5] IDAE, *National Action Plan for Renewable Energy in Spain (PANER) 2011 - 2020*. 2010.
- [6] *Directive 2009/28/EC of the European Parliament and of the Council of 23 April 2009 on the promotion of the use of energy from renewable sources and amending and subsequently repealing Directives 2001/77/EC and 2003/30/EC*. 2009.
- [7] *Spanish Law of Electric Sector 54/1997, (BOE n.º 285, november 28th, 1997)*.
- [8] *Royal Decree 661/2007, (BOE n.º 126, may 25th, 2007), by regulating the activity of electricity production in the Special Regime*. 2007.
- [9] RETScreen International. *Renewable energy project analysis software*. Available from: <http://www.retscreen.net/>.
- [10] Balciunas, P. and Zdanekus, N., *Harmonization of hydropower plant with the environment*. *Renew. & Sustainable Energy Reviews*, 2007. **11**(6): p. 1260-1274.
- [11] Cuesta Diego, L. and Vallarino, E., *Aprovechamientos hidroeléctricos*. Vol. II. 2000, Madrid, Spain: Colegio de Ingenieros de Caminos, Canales y Puertos.
- [12] Singal, S.K., Saini, R.P. and Raghuvanshi, C.S., *Analysis for cost estimation of low head run-of-river small hydropower schemes*. *Energy for Sustainable Development*, 2010. **14**(2): p. 117-126.
- [13] Ogayar, B. and Vidal, P.G., *Cost determination of the electro-mechanical equipment of a small hydro-power plant*. *Renewable Energy*, 2008. **34**(1): p. 6-13.
- [14] Karlis, A.D. and Papadopoulos, D.P., *A systematic assessment of the technical feasibility and economic viability of small hydroelectric system installations*. *Renewable Energy*, 2000. **20**(2): p. 253-262.
- [15] Tawfik, H., Rubenstein, C.P., Blackman, N. and Mahajan, D. *Economic analysis of renewable energy systems*. in *2006 IEEE Long Island Systems, Applications and Technology Conference, LISAT*. 2006. Long Island, NY.
- [16] Kosnik, L., *The potential for small scale hydropower development in the US*. *Energy Policy*. **38**(10): p. 5512-5519.
- [17] Ibrahim, M., Anisuzzaman, M., Kumar, S. and Bhattacharya, S.C., *Demonstration of PV micro-utility system for rural electrification*. *Solar Energy*, 2002. **72**(6): p. 521-530.
- [18] El-Shimy, M., *Viability analysis of PV power plants in Egypt*. *Renewable Energy*, 2009. **34**(10): p. 2187-2196.
- [19] Hourri, A., *Solar water heating in Lebanon: Current status and future prospects*. *Renewable Energy*, 2006. **31**(5): p. 663-675.
- [20] Himri, Y., Stambouli, A.B. and Draoui, B., *Prospects of wind farm development in Algeria*. *Desalination*, 2009. **239**(1-3): p. 130-138.
- [21] Kavvadias, K.C., Tosios, A.P. and Maroulis, Z.B., *Design of a combined heating, cooling and power system: Sizing, operation strategy selection and parametric analysis*. *Energy Conversion and Management*. **51**(4): p. 833-845.
- [22] Katiraei, F. and Abbey, C. *Diesel plant sizing and performance analysis of a remote wind-diesel microgrid*. in *2007 IEEE Power Engineering Society General Meeting, PES*. 2007. Tampa, FL.
- [23] Confederación Hidrográfica del Duero. *Resumen de datos históricos de la estación de aforo de Cordovilla la Real*. 2007; Available from: <http://www.chduero.es>.
- [24] European Small Hydropower Association ESHA *State of the art of small hydropower in EU-25*. 2005.

**Figure captions**

Figure 1: Regional distribution of SHP capacity in Spain. (Source: prepared from REE data in ref. [3])

Figure 2: SHP facility: (a) Aerial photography of the plant; (b) Bypass channel; (c) Return of the bypass to the main river.

Figure 3: Different electromechanical elements of the SHP plant: (a) zenithal view of the turbines; (b) electric generator; (c) multiplier; (d) control system.

Figure 4: Annual total production (MWh) of the SHP facility from 1998 to 2009.

Figure 5: RETScreen model flow diagram.


Figure 6: Flow duration curve for the River Pisuerga. (Source: prepared from Confederación Hidrográfica del Duero data in ref. [23])

Figure 7: Turbine performance as a function of the flow duration curve and the number of working turbines.

Figure 8: Summary of the initial costs of the facility.

Figure 9: Summary of financial analysis: cumulative cash flow calculated by RETScreen over the estimated cycle of life of the plant and the actual cash flow for the ten years of operation.

Figure\_1





(a)



(b)



(c)

Accepted Manuscript




(a)


(b)

(c)




(d)






Accepted Man

Figure\_6








Figure\_7



Figure\_8



Figure\_9



## Tables

Table 1: Evolution of the Fixed Electrical tariff for electricity generation under the Special Regime applied to SHP in Spain (1998-2009).

Year	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009
c€/ kWh	6.778	6.685	6.365	6.365	6.383	6.491	6.548	8.964	8.979	7.382	8.248	8.500

Table 2: Annual Electrical Production (GWh) of the SHP facility Asturwatt in the period under evaluation (1998-2009).

Year Month	1998	1999	2000	2001 <sup>1</sup>	2002	2003	2004	2005	2006	2007	2008	2009
<b>Jan</b>	0	130.10	233.21	0	113.18	142.72	244.57	134.71	132.18	201.90	123.13	187.25
<b>Feb</b>	0	108.43	177.26	0	90.29	127.50	204.09	132.64	108.57	194.21	114.11	194.24
<b>Mars</b>	0	72.22	122.69	0	142.48	168.99	223.86	154.32	215.29	224.04	116.32	222.52
<b>Apr</b>	0	52.63	137.30	0	104.80	190.37	182.14	139.66	186.33	203.09	171.97	151.07
<b>May</b>	0	76.25	201.89	0	32.05	183.68	132.69	89.71	73.53	206.93	220.05	94.56
<b>Jun</b>	45.65	49.61	137.88	0	20.07	119.47	100.07	110.07	49.28	190.66	127.72	87.19
<b>Jul</b>	154.15	90.86	144.79	0	97.07	109.24	94.02	145.75	61.79	141.29	104.37	136.08
<b>Aug</b>	134.50	74.74	141.84	0	70.68	131.65	90.98	127.68	69.13	123.75	108.53	118.72
<b>Sept</b>	103.46	30.67	45.00	0	0.00	66.01	48.59	21.83	20.41	124.99	97.68	58.20
<b>Oct</b>	24.48	55.58	7.99	28.80	43.25	81.79	31.53	0.19	49.83	59.16	0.54	8.60
<b>Nov</b>	7.56	199.22	114.41	74.97	94.74	130.75	92.92	83.60	131.31	27.58	41.85	18.21
<b>Dec</b>	0.22	186.48	14.40	67.07	150.87	187.23	113.80	106.08	200.14	28.18	175.96	76.65
<b>Total</b>	470.02	1126.80	1478.66	170.84	959.46	1639.41	1559.25	1246.24	1297.78	1725.80	1402.22	1353.30

<sup>1</sup> The electrical production was null from January to September of 2001 due to damage caused by a major flood and subsequent repairs to a large part of the electromechanical elements of the installation

Table 3: Energy model data for the SHP project

	Unit	Location of meteorological data	Location of the project
Latitude	°N	42.0	42.2
Longitude	°E	-4.5	-4.3
Drop in elevation	M	757	780
Heating design temperature	°C	-2.3	
Air conditioning design temp.	°C	26.1	
Soil temp. amplitude	°C	19.4	

Table 4: Summary of the technical performance characteristic of the semi-kaplan turbine of Asturwatt.

Design flow	18 m <sup>3</sup> /s
Design Coefficient	4.5
Turbine peak efficiency	78.5%
Flow at Peak Performance	13.5 m <sup>3</sup> /s
Turbine Efficiency at Design Flow	78.1%
Maximum Hydraulic Losses	35%
Miscellaneous Losses	2%
Availability	97%

Table 5: Equipment data analysis: summary of results

Power Capacity	363 kW
Available flow adjustment Factor	97%
Electricity exported to grid	1479 MWh

Table 6: Summary of financial results of the SHP project calculated by RETScreen

Pre-tax IRR- equity	9.2 %
Pre-tax IRR- assets	6.9 %
After-tax IRR-equity	6.2 %
After-tax IRR-assets	4.5 %
Simple payback	11.2 year
Net present Value (NPV)	2349625 €
Annual life cycle savings (50 years)	46992 €/year
Benefit-Cost (B-C) ratio	4.07
Debt Service Coverage	1.55
Energy Production Cost	50.52 €/MWh.